

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		1. CONTRACT ID CODE	Page of Pages 1 7
---	--	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. 002		3. EFFECTIVE DATE April 14, 2000	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY Bureau of Reclamation Lower Colorado Region P.O. Box 61470 Boulder City NV 89006-1470		CODE LC-3114	7. ADMINISTERED BY (If other than Item 6) CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and ZIP code)			(T)	9A. AMENDMENT OF SOLICITATION NO. 00-SI-30-0023
			T	9B. DATED (SEE ITEM 11) March 21, 2000
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 13)
CODE		FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS	
<p>[T] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [ ] is extended, [T] is not extended.</p> <p>Offerors must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:  (a) By completing Items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>	

12. ACCOUNTING AND APPROPRIATION DATA (if required)	
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.	
(T)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. <b>IMPORTANT:</b> Contractor [ ] is not, [ ] is required to sign and return _____ copies to the issuing office.	
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible)	
<u>Project Title:</u> Penstock Tunnel Repairs, Hoover Dam & Powerplants, Boulder Canyon Project, Arizona - Nevada  <u>Purpose of Amendment:</u> The purpose of this amendment is to (1) provide lists of site visit participants that visited the work site on April 6, 7, 10 and 11, 2000 and (2) provide answers to questions submitted by prospective bidders on April 13, 2000.  <u>Receipt of Bids:</u> The date for receipt of bids remains April 20, 2000 at 2 p.m., local time. The place for receipt of bids remains the Bureau of Reclamation, Lower Colorado Regional Office, Annex Building, Room AA-123, Nevada Hwy and Park Street, Boulder City, Nevada.  <u>Acknowledgment:</u> See block 11 above regarding how to acknowledge this amendment. The acknowledgment must be received at the place designated for receipt of offers (see block 8 of the "Solicitation, Offer, and Award," Standard Form 1442).  <u>Bid Modification:</u> See block 11 above if you have submitted your bid and now desire to modify it or withdraw it.	
(Continued on following page(s))	

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.	
15A. NAME AND TITLE OF SIGNER (TYPE OR PRINT)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR	16B. UNITED STATES OF AMERICA
15C. DATE SIGNED	BY _____
(Signature of person authorized to sign)	(Signature of Contracting Officer)
16C. DATE SIGNED	

Description of the Change:

1. The following attachments are incorporated into the solicitation:
  - (a) Lists of "Site Visit Participants" dated April 6, 7, 10 and 11, 2000 pages.
  - (b) List of "Questions and Answers" page.

**SITE VISIT PARTICIPANTS**

**SOLICITATION NO. 00-SI-30-0023  
PENSTOCK TUNNEL REPAIRS, HOOVER DAM AND POWERPLANTS  
LOWER COLORADO DAMS FACILITIES OFFICE  
BOULDER CANYON PROJECT  
ARIZONA - NEVADA**

---

**FOR  
HOOVER DAM  
BOULDER CITY, NEVADA**

**APRIL 6, 2000**

**SIGN IN SHEET**

Name & Address of Firm	Representative/Title	Telephone No.
SSW Mechanical 670 Oleander Road Palm Springs, CA	Greg Wood	

**SITE VISIT PARTICIPANTS**

**SOLICITATION NO. 00-SI-30-0023  
PENSTOCK TUNNEL REPAIRS, HOOVER DAM AND POWERPLANTS  
LOWER COLORADO DAMS FACILITIES OFFICE  
BOULDER CANYON PROJECT  
ARIZONA - NEVADA**

---

**FOR  
HOOVER DAM  
BOULDER CITY, NEVADA**

**APRIL 7, 2000**

**SIGN IN SHEET**

<b>Name &amp; Address of Firm</b>	<b>Representative/Title</b>	<b>Telephone No.</b>
Morrison Knudsen	Robert Law Jerry Shelton	
Brandt Development	Bob Lange	

**SITE VISIT PARTICIPANTS**

**SOLICITATION NO. 00-SI-30-0023  
PENSTOCK TUNNEL REPAIRS, HOOVER DAM AND POWERPLANTS  
LOWER COLORADO DAMS FACILITIES OFFICE  
BOULDER CANYON PROJECT  
ARIZONA - NEVADA**

---

**FOR  
HOOVER DAM  
BOULDER CITY, NEVADA**

**APRIL 10, 2000**

**SIGN IN SHEET**

Name & Address of Firm	Representative/Title	Telephone No.
Peter Kiewit Construction	Anne Guthro Andrew Rule	
Safeway Steel Products Inc.	Mike Bliss Erick Terzoli	

**SITE VISIT PARTICIPANTS**

**SOLICITATION NO. 00-SI-30-0023  
PENSTOCK TUNNEL REPAIRS, HOOVER DAM AND POWERPLANTS  
LOWER COLORADO DAMS FACILITIES OFFICE  
BOULDER CANYON PROJECT  
ARIZONA - NEVADA**

---

**FOR  
HOOVER DAM  
BOULDER CITY, NEVADA**

**APRIL 11, 2000**

**SIGN IN SHEET**

Name & Address of Firm	Representative/Title	Telephone No.
JCI Metal Products	Jerry Eisenhower Richard Bartlett	
ASI	Terry Eckenwiler Jack Eckenwiler	
FHI	Skip Jensen	
Eagle Scaffold	Matt Noto Darren Fidler	

**SOLICITATION NO. 00-SI-30-0023**  
**PENSTOCK TUNNEL REPAIRS, HOOVER DAM AND POWERPLANTS**  
**LOWER COLORADO DAMS FACILITIES OFFICE**  
**BOULDER CANYON PROJECT**  
**ARIZONA - NEVADA**

<b>QUESTION No. 11</b>	Will it be acceptable to use the penstock pipe to partially found the scaffold to? (e.g., can a leg of the scaffold rest on the penstock pipe? Required repairs?)
<b>RESPONSE</b>	It is not acceptable to use the penstock to support scaffolding.
<b>QUESTION No. 12</b>	Can the contractor assume he/she can utilize the adits for some degree of material storing/staging? What about the viewing platforms?
<b>RESPONSE</b>	The contractor may utilize adits for material storing/staging provided access is not blocked. The contractor is not allowed to use the viewing platforms for material storing/staging.
<b>QUESTION No. 13</b>	If the existing stiffeners in the lower penstock canopy are not redwood as shown, but are in good condition, will they be required to be replaced?
<b>RESPONSE</b>	Yes, they will have to be replaced.
<b>QUESTION No. 14</b>	In the lower penstocks, while moving the 50' scaffold, will it be possible to disconnect the vertical ventilation drops to let the scaffold pass?
<b>RESPONSE</b>	Yes, they can be temporarily removed.
<b>QUESTION No. 15</b>	If hazardous materials requiring disposal are encountered during the course of the work, will the Bureau be the generator?
<b>RESPONSE</b>	Yes, the Bureau of Reclamation will be the generator.
<b>QUESTION No. 16</b>	Specification Section C.6.1.d indicates metal scaffolds will be listed by Underwriter Laboratories or Factory Mutual Engineering. If an internally designed custom scaffold system is contemplated by the Contractor, will his Professional Engineers design and stamp be acceptable or will a further UL review be necessary?
<b>RESPONSE</b>	The scaffolding will be acceptable with the contractor's professional engineer's design and stamp.